

KARNATAKA VETERINARY, ANIMAL AND FISHERIES SCIENCES UNIVERSITY, BIDAR
COLLEGE OF FISHERIES, MANGALURU-575002

No.FCM/EB/2020-21

Date: 04.12.2020

QUOTATION ENQUIRY

Sub: Quotation towards the providing and fixing Foot light, Tube light, Wiring at Auditorium and in Toilets at College of Fisheries, Mangaluru-reg.

With reference to the above cited subject, sealed quotations are invited for following work. The quotations should reach the undersigned on or before **12.12.2020**.

Please refer **Schedule B** page for detailed work description.

Note:

1. Quotations received after last date and having description of the materials incomplete will not be entertained.
2. Quotations should be raised in favour of "**Dean, College of Fisheries, Mangaluru**"
3. Write compulsory reference number and quotations last date on sealed covers.
4. Rates should be quoted in Indian currency per unit.
5. Details of tax etc. should be mentioned separately.
6. GST/ PAN/ TIN numbers should be mentioned in the quotation.
7. Lowest quotation rate would be accepted.
8. The total amount for all the above items will considered for calculation and placing order is subject to meeting all the above conditions.

Yours Faithfully,

Dean (Fisheries)
DEAN (FISHERIES)
College of Fisheries
Mangaluru
Mangalore ?

Copy to:

- 1) Notice Board, College of Fisheries, Mangaluru
- 2) Notice Board, Technology wing, Hoige Bazar
- 3) Assistant Comptroller, COF, Mangaluru for kind information
- 4) College Website: www.cofm.edu.in

Schedule - B

Name of work: Providing and fixing Foot light, Tube light, Wiring at Auditorium and in Toilets, at College of Fisheries, Mangaluru

Amount of Estimate : Rs. 86300.00

Name of Contractor :

Notification No:

Last date for submission

No. of items : 14 (Fourteen only)

Sl. No	Particulars	Qty	Unit	Rate as per SR	Amount	Rate quoted by contractor in figures and words	Amount
1	Supplying and wiring adopting loop system in existing PVC conduit/casing capping using 1100V grade, COPPER conductor flexible multistrand FRLS PVC insulated, 2 X 1.5Sq.mm. Cable confirming to the GTP, with a 6Amps flush type SP control switch shall be fixed on the existing plastic sheet / gang box, the other end of the wires shall be terminated with sufficient loose length in a wood/PVC round block.complete for each outlet.Short point upto 3 Mtr from tapping point out let via switch	15.00	Ponit	191.10	2871.00		
2	Supplying and wiring adopting loop system in existing PVC conduit/casing capping using 1100V grade, COPPER conductor flexible multistrand FRLS PVC insulated, 2 X 1.5Sq.mm. Cable confirming to the GTP, with a 6Amps flush type SP control switch shall be fixed on the existing plastic sheet / gang box, the other end of the wires shall be terminated with sufficient loose length in a wood/PVC round block.complete for each outlet.Medium point above 3 mtr upto 6 mtr from tapping point to out let via switch	3.00	Ponit	269.50	808.50		

No.of corrections ()

No.of overwriting ()

Signature of Contractor

Professor and Head

3	Supplying and wiring adopting loop system in existing PVC conduit/casing capping using 1100V grade, COPPER conductor flexible multistrand FRLS PVC insulated, 2 X 1.5Sq.mm. Cable confirming to the GTP, with a 6Amps flush type SP control switch shall be fixed on the existing plastic sheet / gang box, the other end of the wires shall be terminated with sufficient loose length in a wood/PVC round block.complete for each outlet.Long point above 6 mtr upto 10 mtr from tapping point to out let via switch	3.00	Ponit	399.30	1197.90		
4	Supplying heavy gauge PVC Conduit pipe dia mm thick confirming to IS 2509 with suitable size bends, junction boxes, adhesive paste etc., and fixing using inverted wood plugs in case of RCC wall/ stone structure or rawl plugs in case of brick walls and cement plastering the damaged portion using heavy gauge saddles at an interval of 700mm using NF screws pvc pipe. 19/20mm dia 2mm thick	180.00	Rmt	59.40	10692.00		
5	Wiring for lighting/power circuit using one of FRLS PVC insulated 1100V grade, multistrand Copper with low conductor resistance single core wire in open or concealed system of wiring with specified IS-694:1990 & confirming to GTP of GROUP-A . 1 Sqmm	295.00	Rmt	14.30	4218.50		

No.of corrections ()

No.of overwriting ()

Signature of Contractor

Professor and Head

6	Wiring for lighting/power circuit using one of FRLS PVC insulated 1100V grade, multistrand Copper with low conductor resistance single core wire in open or concealed system of wiring with specified IS-694:1990 & confirming to GTP of GROUP-A . 1.5sqmm	78.00	Rmt	20.46	1595.88		
7	Supplying and fixing surface flush mounting unbreakable PVC modular Box suitable for mounting modular switch plates with due groove cutting in Brick/C.C. wall, including necessary rawl plugs, Machine /NF screws etc., complete. 1-3 way	5.00	Each	91.30	456.50		
8	Supplying and flush mounting powder coated/Galvanised metal box suitable for mounting modular switch plates. The box should be firmly flush mounted after due groove cutting in Brick/Stone/CC wall 1-3 way	5.00	Each	100.10	500.50		
9	Supplying and fixing superior quality modular switch mounting polycarbonate plate with necessary supporting back plate with required no.s machine screws, bolts nuts etc., complete on the existing metal/PVC box. 1 to 3 module	5.00	Each	119.90	599.50		
10	Supplying CFL mirror light fitting with 1x11W CFL lamp, choke, Perspex cover and completely wired for use on 230V 50Hz AC supply	17.00	Each	712.80	12117.60		

No.of corrections ()

No.of overwriting ()

Signature of Contractor

Professor and Head

11	Supplying of 2' feet - LED PVC Square Battern ..W with high quality diffuser with Life of 25000 burning hours & 70% lumen maintenance with CRI>80. Power Input: 220-240V @ 50Hz & Power factor >0.9 along with CE approved drivers. 5years Warranty against any manufacturing defect working under standard electrical condition. LED light fighting 4'-28 watts	19.00	Each	1951.40	37076.60		
12	Supplying Halogen Lamps fitting complete with lamp. The fitting shall be non corrossive high pressure die cast aluminium housing with low copper content grey powder coated finish including wiring, suitable to operate on 230/250 Volts 50Hz AC supply with halogen lamp. 500 watts	3.00	Each	1603.80	4811.40		
13	Fixing all types and all capacities of fluoesent/false ceiling / spot light / CFL / LED fittings indoor on the wall/ ceiling / rafters / girders using 23/0.0076" twin twisted PVC insulated wires, required Nos of round blocks and clamps. On wall / ceiling / rafters / girders	38.00	Each	107.80	4096.40		
14	Supply and fixing of Bakelite D.P socket switch with / without Neon indicator over existing wood board or flush mounting in plastic plates/nitches as per IS 1293 and IS 3854 16Amp Flush SP Switch	23.00	Each	161.70	3719.10		
		Total Rs. 84761.38					

No.of corrections ()

No.of overwriting ()

Signature of Contractor

Professor and Head